




WIRING OF MCC2/MTC THERMOSTAT AND CONTACTOR

Where the floor heating load exceeds 3400W a contactor needs to be installed




Contactor Wiring Details


Max 40A
Heat Load 9600W



Max 60A
Heat Load 14400W



Max 24A per phase
Heat Load 17280W
415 V 3ph



NOTE: Earth screen of all heating cables is to be connected to EARTH